



Bestätigung

Confirmation · Conformité · Conformidad

1000 L maximum greywater-inflow for grey2clean

Dear Sir or Madam,

We hereby confirm that the grey water purification plant

**grey2clean 760L/d
with Platin 3000 L tank**

is suitable for a temporary inflow overload of maximum of 1,000 L per day. Up to this hydraulic load, the inflowing wastewater is temporarily buffered in the tank and discharged through an fine filter with an integrated throttle. Hydraulic overload is therefore excluded.

The hydraulic performance of the grey2clean was proven in a hydraulic test. During the test, a grey2clean for 760 l / d was fed with a flow profile of 1,000 L/d. There was no overloading of the system.

Teningen, 27.10.2020

Ralf Oestreicher
Teamleiter Produktmanagement Abwasser